

2018 Water Quality

Consumer Confidence Report

Pomunk Water Company 008-0084

Is my water safe?

Last year, as in years past, your tap water met all U.S. Environmental Protection Agency (EPA) and state drinking water health standards. Pomunk Water Company vigilantly safeguards its water supplies and once again we are proud to report that our system has not violated a maximum contaminant level or any other water quality standard.

Do I need to take special precautions?

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Water Drinking Hotline (800-426-4791).

Where does my water come from?

The sources of the drinking water for the Bryans Road System are the Patapsco and Patuxent Aquifers. An aquifer is an underground reservoir or deposit of water that is tapped by drilling wells and pumping the water to the surface for distribution. The earth between the surface and the underground aquifer helps to purify the water, making it easier to treat the water supply before it is pumped into the water distribution system. The Bryans Road system is served by 4 wells (Well #6, Strawberry Hills, South Hampton 1 and South Hampton 2).

Source water assessment and its availability

Source water Assessment was conducted by the Maryland Department of the Environment's Water Supply Program. It is available through the water supply program by calling 1 (800) 633-6101.

Why are there contaminants in my drinking water?

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's (EPA) Safe Drinking Water Hotline (800-426-4791). The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity. Microbial contaminants, such as viruses and bacteria that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife. Inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban storm water runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming. Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses. Organic Chemical Contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff, and septic systems. Radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities. In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. Food and Drug Administration (FDA) regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Lead Statement

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Pomunk Water Company is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your drinking water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the EPA Safe Drinking Water Hotline at 1-800-426-4791 or at <http://www.epa.gov/safewater/lead>.

How can I get involved?

The most important impact the consumer can have on the water supply is to recognize the finite nature of our water supply and to practice water conservation principles.

For more information please contact: Water Services, Inc., 14E Irongate Dr., Waldorf, MD. 20602 Phone: 301-645-2798

Violations (Bryans Road System):

Violation Type: Arsenic routine monitoring 01/01/2016 – 12/31/2018. The Bryans Road System failed to test the drinking water for the contaminant and period indicated. Because of this failure, they cannot be sure of the quality of the drinking water during the period indicated.

Water Quality Data Table

The table below lists all of the drinking water contaminants that we detected during the calendar year of this report. The presence of contaminants in the water does not necessarily indicate that the water poses a health risk. Unless otherwise noted, the data presented in this table is from testing done in the calendar year of the report. The EPA or the State requires us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently.

Tap water samples were collected from homes throughout the service area and tested for lead and copper				
Contaminant	MCL	Detected Level	MCLG	Source of Contamination
Haloacetic Acids, ug/l (Pomunk System)	60	2.24	N/A	by-product of drinking water chlorination
Haloacetic Acids, ug/l (Bryans Road System)	60	2.0	N/A	by-product of drinking water chlorination
Trihalomethanes, ug/l (Pomunk System)	80	31.7	N/A	by-product of drinking water disinfection
Trihalomethanes, ug/l (Bryans Road System)	80	18.0	N/A	by-product of drinking water disinfection
	Action Level	Detected Level	MCLG	Source of Contamination
Copper, mg/l (Bryans Road System) 2017	1.3	0.06	1.3	leaching from plumbing
Lead, ppb	15	0	0	leaching from plumbing

Regulated Contaminants	MCL	Detected Level	MCLG	Source of Contamination
Fluoride, mg/l (Bryans Road System)	4	0.73	4	erosion of natural deposits
Chlorine, mg/l (Bryans Road System)	4	1.6	4	water additive used to control microbes
Chlorine, mg/l (Pomunk System)	4	1.4	4	water additive used to control microbes
Gross Alpha, pCi/l (Bryans Road System)				
Well 6 (2015)	15	5.4	0	erosion of natural deposits
So. Hampton (2014)	15	3.9	0	erosion of natural deposits

Definitions:

- (1) **Maximum Contaminant Level (MCL):** the highest level of a contaminant allowed to be present in drinking water
- (2) **Maximum Contaminant Level Goal (MCLG):** the level of contaminant in drinking water below which, there is no known or expected health risk
- (3) **Action Level:** the concentration of a contaminant, which, if exceeded, triggers treatment or other requirements, which the system must follow
- (4) **mg/l:** milligrams per liter, or parts per million
- (5) **ug/l:** micrograms per liter, or parts per billion
- (6) **mrem/yr:** millirems per year (a measure of radiation absorbed by the body)
- (7) **pCi/l:** picocuries per liter (a measure of radiation)
- (8) *50 EPA considers 50 pCi/l a level of concern for Beta particles

For more information please contact: Water Services, Inc., 14E Irongate Dr., Waldorf, MD. 20602 Phone: 301-645-2798